



SCHOOL ADMINISTRATIVE UNIT #48

SERVING CAMPTON • ELLSWORTH • HOLDERNESS • PEMI-BAKER REGIONAL
PLYMOUTH • RUMNEY • THORNTON • WATERVILLE VALLEY • WENTWORTH

January 7, 2019

Campton Elementary School
1110 NH 175
Campton, NH 03223

RE: Lead Tap Water Results
Room 9 Classroom Sink - Mrs. Nolan's Room

Dear Parents,


On February 8, 2018, Governor Sununu signed Senate Bill 247 Prevention of Childhood Lead Poisoning. This law requires, among other actions, that all schools and licensed childcare facilities test lead in drinking water at all locations where water is available for consumption by children. The first round of testing is required to be completed by July 1, 2019. CES has completed its testing of all possible drinking water sources and has received the results of this testing.

A drinking water sample for lead was collected from the Room 9 Classroom sink and the results were .039 mg/L. The action level for lead established by the U.S. Environmental Protection Agency (EPA) is **0.015 mg/L**. If this action level is exceeded, then treatment or other requirements must be followed to assure the safety of your drinking water.

Due to the testing results, remediation for the Room 9 Sink will be to label it **Non-Potable Sink, Not for Consumption**. Lastly, the water to this source will be shut off.

Should you have any questions, please do not hesitate to contact us.

Sincerely,



Mark Halloran
Superintendent of Schools